



## IES INDOOR REPORT

PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

### DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002  
 [TEST] L041505601  
 [TESTLAB] LIGHT LABORATORY, INC.  
 [ISSUE DATE] 4/20/2015  
 [MANUFAC] PRUDENTIAL LTG.  
 [LUMCAT] P4018-LED35-LO-D1  
 [LUMINAIRE] 19-1/4"DIA. X 5"H. LED LUMINAIRE  
 [MORE] DIFFUSED LENS  
 [BALLASTCAT] OSRAM OPTOTRONIC  
 [BALLAST] INPUT: 120-277VAC  
 [LAMPPOSITION] 0,0  
 [LAMPCAT] N/A  
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND  
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.  
 [ INPUT] 120VAC  
 [ TEST PROCEDURE] IESNA:LM-79-08

### CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1369
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	72
Total Luminaire Watts	19
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Circular
Luminous Length (0-180)	2.04 ft (Diameter)
Luminous Width (90-270)	2.04 ft (Diameter)
Luminous Height	0.00 ft

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES**

**LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1483	1483	1483
55	1418	1418	1418
65	1342	1342	1342
75	1115	1115	1115
85	698	698	698

IES INDOOR REPORT  
PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

CANDELA TABULATION

	<u>0</u>
0	488.48
5	485.47
10	478.59
15	466.55
20	451.07
25	430.86
30	407.64
35	380.98
40	351.31
45	318.63
50	284.23
55	247.25
60	212.85
65	172.43
70	129.86
75	87.72
80	48.59
85	18.49
90	0.00

**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES**

**ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	177.82	N.A.	13.00
0-30	376.43	N.A.	27.50
0-40	614.74	N.A.	44.90
0-60	1082.51	N.A.	79.10
0-80	1346.06	N.A.	98.30
0-90	1369.35	N.A.	100.00
10-90	1323.22	N.A.	96.60
20-40	436.92	N.A.	31.90
20-50	682.78	N.A.	49.90
40-70	637.98	N.A.	46.60
60-80	263.55	N.A.	19.20
70-80	93.34	N.A.	6.80
80-90	23.29	N.A.	1.70
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1369.35	N.A.	100.00

Total Luminaire Efficiency = N.A. %

**ZONAL LUMEN SUMMARY**

Zone	Lumens
0-10	46.13
10-20	131.69
20-30	198.61
30-40	238.31
40-50	245.86
50-60	221.91
60-70	170.20
70-80	93.34
80-90	23.29
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


**IES INDOOR REPORT**  
**PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES**

**COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD**

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	98	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	26	52	39	32	26	38	31	26	37	31	26	36	30	26	24

POLAR GRAPH



Maximum Candela = 488.48 Located At Horizontal Angle = 0, Vertical Angle = 0  
# 1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)  
# 2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)