



Lighting Sciences, Inc.
UL Verification Services
7826 E. Evans Rd.
Scottsdale, Arizona 85260 USA
P: 480-991-9260 F: 480-991-0375
lsi@ul.com



www.lightingsciences.com

INDEPENDENT TEST LABORATORY REPORT No. 31679

Description:

PRUDENTIAL LIGHTING - LED COVE LUMINAIRE, CAT# P59-LED3-04-W-UNV
WITH WHITE INTERIOR AND NO LENS
ONE EPTRONICS LD50W-36-C1400-RD DRIVER OPERATING AT 120 VAC AND 40 WATTS

The sample(s) was(were) tested in accordance with the following applied standards/regulations:

ANSI/UL 1598-2008 Luminaires: In-Situ Temperature Measurement Test (ISTMT)

Prepared for:

PRUDENTIAL LIGHTING

LOS ANGELES, CA

Approved by:

JIM DOMIGAN

VS SUPERVISOR

APR 9, 2013


This report shall not be reproduced except in full without the written approval of the laboratory. The results in this report apply to the test sample(s) mentioned above at the time of the testing period only and are not to be used to indicate applicability to other similar products.

LIGHTING SCIENCES, INC.
7826 E. EVANS RD.
SCOTTSDALE, AZ, USA 85260

INDEPENDENT TEST LABORATORY REPORT No. 31679

PRUDENTIAL LIGHTING - LED COVE LUMINAIRE, CAT# P59-LED3-04-W-UNV
WITH WHITE INTERIOR AND NO LENS
ONE EPTRONICS LD50W-36-C1400-RD DRIVER OPERATING AT 120 VAC AND 40 WATTS

LED Thermocouple Location



Driver Thermocouple Location



Test Temperature:	25.0 °C
LED Temperature:	50.7 °C
Driver Temperature:	52.8 °C
Maximum LED Current:	76.5 mA

Temperatures are offset to an ambient temperature of 25°C as described in UL1598-2008