



IES INDOOR REPORT

PHOTOMETRIC FILENAME : P9040-LED35-MO-FWA.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] L041411805
 [TESTLAB] LIGHT LABORATORY, INC.
 [ISSUE DATE] 5/14/2014
 [MANUFAC] PRUDENTIAL LIGHTING
 [LUMCAT] P9040-LED35-MO-FWA
 [LUMINAIRE] 48"SQ. X 7-5/8"H. LED LUMINAIRE
 [MORE] DIFFUSED LENS
 [BALLASTCAT] OSRAM OPTOTRONIC OT
 [BALLAST] INPUT: 120-277VAC
 [LAMPPOSITION] 0,0
 [LAMPCAT] N/A
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
 [INPUT] 120VAC
 [TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	8771
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	80
Total Luminaire Watts	110
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Circular
Luminous Length (0-180)	3.83 ft (Diameter)
Luminous Width (90-270)	3.83 ft (Diameter)
Luminous Height	0.00 ft

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P9040-LED35-MO-FWA.IES

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2664	2664	2664
55	2545	2545	2545
65	2424	2424	2424
75	2158	2158	2158
85	1908	1908	1908

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P9040-LED35-MO-FWA.IES

CANDELA TABULATION

	0
0	3091.28
5	3073.60
10	3027.36
15	2953.92
20	2851.92
25	2726.80
30	2579.92
35	2411.28
40	2223.60
45	2018.24
50	1797.92
55	1564.00
60	1343.68
65	1097.52
70	845.92
75	598.40
80	372.64
85	178.16
90	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P9040-LED35-MO-FWA.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	1125.24	N.A.	12.80
0-30	2381.91	N.A.	27.20
0-40	3890.2	N.A.	44.40
0-60	6849.81	N.A.	78.10
0-80	8572.71	N.A.	97.70
0-90	8771.16	N.A.	100.00
10-90	8479.21	N.A.	96.70
20-40	2764.96	N.A.	31.50
20-50	4321.48	N.A.	49.30
40-70	4045.17	N.A.	46.10
60-80	1722.9	N.A.	19.60
70-80	637.35	N.A.	7.30
80-90	198.45	N.A.	2.30
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	8771.16	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	291.95
10-20	833.29
20-30	1256.67
30-40	1508.28
40-50	1556.52
50-60	1403.1
60-70	1085.55
70-80	637.35
80-90	198.45
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : P9040-LED35-MO-FWA.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	97	94	97	94	91	93	90	88	90	87	85	83
2	99	90	83	77	96	88	82	76	85	79	75	81	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	69	60	54	66	59	53	64	58	52	62	56	52	50
5	76	63	53	47	73	61	53	46	59	52	46	57	51	45	55	50	45	43
6	70	56	47	41	68	55	47	41	53	46	40	52	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	49	41	36	47	40	35	46	40	35	33
8	60	47	38	32	59	46	38	32	44	37	32	43	36	32	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	29	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24

POLAR GRAPH



Maximum Candela = 3091.28 Located At Horizontal Angle = 0, Vertical Angle = 0

1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)

2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)