IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] BALLABS TEST NO. 21002.0
[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC
[ISSUEDATE] 2023-04-25
[MANUFAC] WILLIAMS INDOOR
[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO
[LUMINAIRE] SL LED SLIMLINE ARCHITECTURAL LUMINAIRE
[MORE] 1.375 WIDE ALUM CHANNEL w/1"WIDE WHITE RADIAL ACRYLIC LENS
[LUMCAT] SL-4-L10-850-RD-DIM-UNV
[LAMPCAT] HLM 80 CRI 3500K CCT
[_SEARCH_SOURCETYPE] LED
[_SEARCH_APPLICATION] INDOOR, COVE, CLASSROOM
[_SEARCH_MOUNTING] SURFACE, WALL

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4114
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	114
Total Luminaire Watts	36
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.28
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Rectangular w/Sides
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.13 ft
Luminous Height	0.05 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	25430	20496	19495
55	24002	18337	17585
65	21363	15762	15649
75	17890	12974	13928
85	9686	10757	12542

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

CANDELA TABULATION

	0.0	22.5	45.0	67.5	90.0
0	1295.32	1295.32	1295.32	1295.32	1295.32
5	1299.56	1293.20	1284.72	1282.60	1284.72
10	1280.48	1274.12	1265.64	1265.64	1269.88
15	1252.92	1246.56	1238.08	1240.20	1240.20
20	1210.52	1204.16	1193.56	1202.04	1204.16
25	1157.52	1151.16	1149.04	1155.40	1159.64
30	1091.80	1091.80	1091.80	1100.28	1098.16
35	1021.84	1021.84	1021.84	1030.32	1036.68
40	937.04	939.16	941.28	956.12	964.60
45	845.88	852.24	858.60	875.56	881.92
50	746.24	752.60	767.44	792.88	805.60
55	650.84	652.96	680.52	701.72	720.80
60	540.60	551.20	589.36	629.64	642.36
65	430.36	447.32	491.84	536.36	555.44
70	328.60	345.56	400.68	455.80	472.76
75	224.72	254.40	315.88	377.36	402.80
80	131.44	163.24	245.92	307.40	334.96
85	44.52	103.88	180.20	241.68	269.24
90	0.00	57.24	133.56	188.68	209.88
95	0.00	29.68	91.16	146.28	165.36
100	0.00	14.84	63.60	108.12	127.20
105	0.00	8.48	44.52	78.44	95.40
110	0.00	6.36	29.68	57.24	67.84
115	0.00	4.24	19.08	40.28	50.88
120	0.00	0.00	10.60	25.44	31.80
125	0.00	0.00	8.48	16.96	21.20
130	0.00	0.00	0.00	10.60	12.72
135	0.00	0.00	0.00	0.00	8.48
140	0.00	0.00	0.00	0.00	0.00
145	0.00	0.00	0.00	0.00	0.00
150	0.00	0.00	0.00	0.00	0.00
155	0.00	0.00	0.00	0.00	0.00
160	0.00	0.00	0.00	0.00	0.00
165	0.00	0.00	0.00	0.00	0.00
170	0.00	0.00	0.00	0.00	0.00
175	0.00	0.00	0.00	0.00	0.00
180	0.00	0.00	0.00	0.00	0.00

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	472.94	N.A.	11.50
0-30	1004.49	N.A.	24.40
0-40	1645.88	N.A.	40.00
0-60	2920.77	N.A.	71.00
0-80	3745.06	N.A.	91.00
0-90	3935.84	N.A.	95.70
10-90	3813.43	N.A.	92.70
20-40	1172.94	N.A.	28.50
20-50	1838.3	N.A.	44.70
40-70	1764.11	N.A.	42.90
60-80	824.29	N.A.	20.00
70-80	335.07	N.A.	8.10
80-90	190.78	N.A.	4.60
90-110	146.60	N.A.	3.60
90-120	168.85	N.A.	4.10
90-130	176.82	N.A.	4.30
90-150	178.08	N.A.	4.30
90-180	178.08	N.A.	4.30
110-180	31.49	N.A.	0.80
0-180	4113.92	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	122.40
10-20	350.54
20-30	531.55
30-40	641.39
40-50	665.36
50-60	609.53
60-70	489.22
70-80	335.07
80-90	190.78
90-100	97.86
100-110	48.74
110-120	22.26
120-130	7.97
130-140	1.27
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	118	118	118	118	115	115	115	115	109	109	109	103	103	103	98	98	98	96
1	106	101	96	92	103	98	94	90	93	90	86	89	86	83	84	82	80	77
2	96	87	80	74	93	85	78	73	81	75	70	77	72	68	73	69	66	63
3	88	76	68	61	85	75	67	60	71	64	59	68	62	57	64	60	55	53
4	80	68	58	51	77	66	57	51	63	55	50	60	54	49	57	52	47	45
5	74	60	51	44	71	59	50	44	56	49	43	54	47	42	51	46	41	39
6	68	54	45	38	66	53	44	38	51	43	37	49	42	37	47	41	36	34
7	63	49	40	34	61	48	40	34	46	39	33	44	38	32	43	37	32	30
8	58	45	36	30	57	44	36	30	42	35	29	41	34	29	39	33	29	27
9	55	41	33	27	53	40	32	27	39	32	27	37	31	26	36	30	26	24
10	51	38	30	25	50	37	30	24	36	29	24	35	28	24	33	28	23	22

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

UGR TABLE - CORRECTED

Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	21.0	22.6	21.4	23.0	23.4	22.7	24.3	23.1	24.7	25.1
	3H	22.5	23.9	22.9	24.3	24.8	25.0	26.4	25.4	26.9	27.3
	4H	22.9	24.3	23.4	24.7	25.2	26.1	27.5	26.6	27.9	28.4
	6H	23.2	24.5	23.7	25.0	25.4	27.3	28.5	27.7	29.0	29.5
	8H	23.3	24.5	23.8	25.0	25.5	27.8	29.1	28.3	29.5	30.0
	12H	23.3	24.5	23.8	24.9	25.5	28.5	29.7	29.0	30.1	30.7
4H	2H	21.8	23.1	22.2	23.6	24.0	23.1	24.5	23.6	24.9	25.4
	3H	23.5	24.6	23.9	25.1	25.6	25.6	26.8	26.1	27.3	27.8
	4H	24.0	25.1	24.5	25.6	26.1	26.9	28.0	27.4	28.4	29.0
	6H	24.4	25.4	25.0	25.9	26.4	28.2	29.2	28.8	29.7	30.2
	8H	24.5	25.4	25.1	25.9	26.5	28.9	29.8	29.4	30.3	30.9
	12H	24.6	25.4	25.1	25.9	26.5	29.7	30.5	30.2	31.0	31.6
8H	4H	24.6	25.5	25.1	26.0	26.5	27.1	28.0	27.6	28.5	29.0
	6H	25.1	25.9	25.7	26.4	27.0	28.6	29.3	29.1	29.9	30.4
	8H	25.3	26.0	25.8	26.5	27.1	29.4	30.1	29.9	30.6	31.2
	12H	25.4	26.0	26.0	26.5	27.2	30.3	30.9	30.9	31.5	32.1
12H	4H	24.7	25.5	25.3	26.1	26.6	27.1	27.9	27.6	28.4	29.0
	6H	25.3	26.0	25.9	26.6	27.2	28.6	29.3	29.2	29.8	30.4
	8H	25.6	26.2	26.1	26.7	27.4	29.5	30.1	30.0	30.6	31.3

Maximum UGR = 32.1

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.

IES INDOOR REPORT
PHOTOMETRIC FILENAME : SL-4-L10-850-RD-DIM-UNV_.IES

POLAR GRAPH



Maximum Candela = 1299.56 Located At Horizontal Angle = 0, Vertical Angle = 5
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (5) (Through Max. Cd.)

Photometric Toolbox (R) Copyright 2002-2019 by Lighting Analysts, Inc.
Calculations based on published IES Methods and recommendations, values rounded for display purposes.
Results derived from content of manufacturers photometric file.