4" ROUND (RD) & FLUTED (FL) DECORATIVE BASE

1. BASE	2. POLE	3. OAH	4. COLOR	5. OPTIONS/ACCESSORIES						
]

MAYIMI M ALLOWARI E EDA (MDH)



DB8

			MAXIMOM ALLOWABLE EPA (MPH)									
1. BASE	2. POLE	3. OAH	SHAFT	WT	85	90	100	110	120	130	140	150
DB8	4R10-125	10' (3.1m)	4" RD x .125"	49	19.4	17.1	13.5	10.8	8.9	7.4	6.3	5.5
DB8	4R12-125	12' (3.7m)	4" RD x .125"	52	15.3	13.4	10.5	8.3	6.7	5.6	4.7	4.0
DB8	4R14-125	14' (4.3m)	4" RD x .125"	56	12.3	10.7	8.2	6.3	5.0	4.1	3.4	2.9
DB8	4R16-125	16' (4.9m)	4" RD x .125"	59	10.0	8.6	6.4	4.8	3.6	2.9	2.4	2.0
DB8	4R10-226	10' (3.1m)	4" RD x .226"	58	23.8	21.0	16.7	13.5	11.1	9.3	8.0	6.9
DB8	4R12-226	12' (3.7m)	4" RD x .226"	64	19.2	16.9	13.3	10.6	8.6	7.2	6.1	5.3
DB8	4R14-226	14' (4.3m)	4" RD x .226"	71	15.9	13.9	10.8	8.4	6.8	5.6	4.7	4.0
DB8	4R16-226	16' (4.9m)	4" RD x .226"	77	12.4	12.3	9.4	7.3	5.7	4.7	4.0	3.3
DB8	4F10-188	10' (3.1m)	4" FL x .188"	55	22.1	19.5	15.4	12.4	10.2	8.5	7.1	6.1
DB8	4F12-188	12' (3.7m)	4" FL x .188"	60	17.6	15.4	12.1	9.6	7.7	6.4	5.3	4.4
DB8	4F14-188	14' (4.3m)	4" FL x .188"	65	14.3	12.5	9.6	7.5	5.9	4.8	3.9	3.2
DB8	4F16-188	16' (4.9m)	4" FL x .188"	70	11.7	10.1	7.6	5.8	4.4	3.5	2.7	2.2

Note: Overall height is measured to top of pole.

Arctic White

Matte Black

Dark Bronze

Dark Green

Weathered Bronze

Bronze Metallic

Matte Aluminum

Medium Grev

Antique Green

Light Grey

Shamrock

Seafoam

Salt and Pepper

Weathered Copper

RAL 4 digit Color

Custom Color

Verde Blue

Corten

Titanium

Black

2. COLOR

WH

ΒI

BLT

DB

TT

DGN

WDB

MDB

VBU

CRT

MAI

MG

AGN

SHK

SFM

WCP

RAI

CUSTOM

Premium Color

LG

Standard Color

3. OPTIONS / ACCESSORIES

FH (Flag holder. Specify location on pole)

FS1 (Single weatherproof fuse holder. Fuse by others.)

FS2 (Double weatherproof fuse holder. Fuse by others.)

LR (Ladder rest. Slips over a 4" O.D. pole.)

PCA-T (Rotatable photocell housing. The housing slips over a 4"/100mm 0.D. pole. A fixture slips over the 4"/100mm 0.D. tenon. Includes an internal twist lock receptacle, and an access cover with integral lens and stainless steel tether. Adds 5"/125mm to the overall height of the pole/fixture assembly. Prewired on the load side and line side for easy installation. Photocell by others.)

PCR (Low profile twist lock photocell receptacle with cast pole cap top. Secures to the top of the pole with three stainless steel set screws. Photocell by others.)

PLT (Plant Hanger. For 4" O.D. poles. (specify location on pole)

RBC (Cast aluminum receptacle housing, integrally welded to the pole. Includes a NEC approved clear weatherproof cover. Does not include a receptacle or internal wiring.)

SPECIFICATIONS

Base shall be cast aluminum #356 alloy, free of any porosity, foreign materials, or cosmetic fillers. Base casting shall be heat treated to a T-6 condition, and of uniform wall thickness, with no warping or mold shifting.

WARNINGS

Caution must be exercised in the selection of a design wind speed when the pole is to be installed in a special wind region (as indicated by the wind map) or in an area where wind speed is unpredictable.

AAL recommends consulting a local engineer when the pole is to be installed in an area that may be subject to extreme weather and exposure

Poles installed on structures such as buildings and bridges may be subjected to vibration, oscillations, and other fatigue effects which are not covered by the AAL warranty.

The use of banners or other appendages can severely affect the loading of a pole. No banner or other appendage should be attached to an AAL pole unless approved by AAL.

If the products are to be used on an existing foundation or on other structures, the customer assumes all responsibility for the structural integrity of the existing foundation, anchorage or structures and all the consequences arising therefrom.

CAUTION

Poles should never be erected without the luminaire installed.

Anchor bolts shall be hot dip galvanized steel. Six galvanized hex nuts and flat washers, and a bolt circle template shall be provided. Anchor bolt for poles are 3/4" x 24" x 3".

CERTIFICATION

Certified UL 1598 in accordance with Article 410 of ANSI/NFPA 70, National Electrical Code.

architectural
arealighting

4" ROUND (RD) & FLUTED (FL) DECORATIVE BASE

DIMENSIONS

